



North Carolina Department of Environment and Natural Resources
Division of Environmental Health

Beverly Eaves Perdue
Governor

Terry L. Pierce
Director

Dee Freeman
Secretary

May 26, 2011

Mr. William Chandler
Chandler Systems, Inc
220 Ohio St
Ashland, OH 44805

Subject: Approval Status of Innovative Approval 2004-2

Dear Mr. Chandler:

An Intent to Suspend Innovative Approval 2004-2 was sent to William Chandler, Chandler Systems, Inc, dated October 26, 2010, for the Pressure Activated Control Liquid Level Controllers and accompanying control panels due to modifications made to the component without prior approval of the On-Site Water Protection Section or the Experimental and Innovative Committee and the failure of the component to perform in the manner specified in the approval.

You were notified pursuant to G.S. 130A-343(c) and 15A NCAC 18A .1969(k) of the following violations of Rules adopted by the North Carolina Commission for Public Health, including Rules 15A NCAC 18A .1969(j) and .1969(k)(2) of the North Carolina Administrative Code in letters dated November 23, 2009 and October 26, 2010. The violations of the Rules are as follows:

1. Modifications were made to the component without the prior approval of the On-Site Water Protection Section [.1969(j)], and
2. Failure of the component to perform in the manner specified in the approval [.1969(k)(2)(A) and (B)].

As of the date of this letter your Innovative Approval, IWWS 2004-2, is suspended and removed from our web page. Local health departments have been informed of the approval status of this system.

If you have any questions, please feel free to contact Tricia Angoli by phone at (919) 715-3272, by fax at (919) 715-3227, or by e-mail at trish.angoli@ncdenr.gov.

Sincerely,

Terry L. Pierce

cc: OSWP Staff
Experimental/Innovative Advisory Committee
Local Health Departments