

State of North Carolina
Department of Environment
and Natural Resources
Division of Environmental Health

Michael F. Easley, Governor
William G. Ross, Secretary
Terry L. Pierce, Director
Andy Adams, Chief



December 1, 2005

Mr. Joe Zimmerman
SJE-Rhombus
22650 County Highway 6
Detroit Lakes, MN 56501

Subject: **Approval of SJE-Rhombus Flow Equalization Panels - Simplex and Duplex**

Dear Mr. Zimmerman:

On December 1, 2005, we completed inspection and testing for the duplex control panel and found that it meets the requirements of Innovative Approval #IWWS 2004-01.

Therefore, we approve the following models of SJE-Rhombus flow equalization control panel:

IFS 1 1 W 1 or 9 0, 1, or 2 4 H 10E 15 A 18A (Simplex)

IFS 3 1 W 1 or 9 0, 1, or 2 4 H 10E 15 A 18A (Duplex)

1 or 9

- Choose for starting device
(1 = 120/208/240 VAC, 9 = 120 VAC)

0, 1, or 2

- Choose for pump full load amps
(0 = 0-7 FLA, 1 = 7-15 FLA, 2 = 15-20 FLA)

Please be aware that these panels are subject to periodic inspections, and should units be found to be in noncompliance with the submission or Innovative Approval, then the approval may be suspended or revoked. Please feel free to contact me if you have any questions pertaining to this approval.

Sincerely,

Tricia Angoli
On-Site Wastewater Engineering

cc: Tommy Carr, Harry Warren, LLC

ON-SITE WASTEWATER SECTION
1642 Mail Service Center, Raleigh, North Carolina 27699-1642
Telephone: 919-715-3272 Fax: 919-715-3227 E-mail: trish.angoli@ncmail.net